

**To:** Benton, Tim[Tim.Benton@WestonSolutions.com]  
**Cc:** Lisichenko, Peter[lisichenko.peter@epa.gov]; Francisco Rodriguez[frodriguez@gesoncall.com]  
**From:** Daly, Eric  
**Sent:** Wed 2/22/2017 9:52:13 PM  
**Subject:** RE: NFB- GNBC HVAC RTU

Thanks Tim.

**From:** Benton, Tim [mailto:Tim.Benton@WestonSolutions.com]  
**Sent:** Wednesday, February 22, 2017 4:12 PM  
**To:** Daly, Eric <Daly.Eric@epa.gov>  
**Cc:** Lisichenko, Peter <lisichenko.peter@epa.gov>; Francisco Rodriguez <frodriguez@gesoncall.com>  
**Subject:** RE: NFB- GNBC HVAC RTU

I have forward the information along to the subcontractor and will send along the response as soon as received. If I do not hear from them by mid-day tomorrow I will follow up with them again.

**From:** Daly, Eric [mailto:Daly.Eric@epa.gov]  
**Sent:** Wednesday, February 22, 2017 2:46 PM  
**To:** Benton, Tim  
**Cc:** Lisichenko, Peter; Francisco Rodriguez  
**Subject:** NFB- GNBC HVAC RTU  
**Importance:** High

Good Afternoon Tim:

Frank has been in discussion with Vastola Heating and they have encountered a problem with the return duct clearance above the drop ceiling. The duct that they had prefabbed for this unit per the drawings will not clear the center support beam for the office area. We are requesting the architect approval on relocating the return in the showroom space to the opposite side of the center beam.

I have attached a figure to better describe. Please request feedback from the architect and let us know if requires further information.

Thanks.

Regards,

Eric M. Daly  
On-Scene Coordinator/Radiological Response Specialist  
US Environmental Protection Agency- Region II

ERRD/RPB/PPS  
2890 Woodbridge Avenue  
Edison, NJ 08837  
[daly.eric@epa.gov](mailto:daly.eric@epa.gov)  
908-420-1707

"We must, indeed, all hang together, or assuredly we shall all hang separately", Benjamin Franklin

CONFIDENTIALITY: This email and attachments may contain information which is confidential and proprietary. Disclosure or use of any such confidential or proprietary information without the written permission of Weston Solutions, Inc. is strictly prohibited. If you received this email in error, please notify the sender by return e-mail and delete this email from your system. Thank you.